

Maren Toohill

From: Tom Clancy
Sent: Wednesday, May 06, 2020 1:24 PM
To: Maren Toohill
Subject: RE: 336 - 338 King St. Water main layout for discussion

Good Afternoon Maren:

I just spoke with Bruce Ringwald about this project. He just wanted to make sure I did not have any concerns about the project before his hearing tomorrow night. I mentioned to him that a neighboring community has educated the ZBA and Planning Boards about implementing residential sprinklers on these types of projects. The two unit dwellings in the back and the existing home at the back, which will become a two unit dwelling are not required to have sprinklers. On my original review of the site, I instructed Bruce to make the access road 10' wide with 5' of pavers on either side to accommodate the fire apparatus. After our phone call today, if the applicants wanted an 8' access road with 5' of pavers on either side, I would be amenable provided the (3) two-unit dwellings have residential fire sprinklers installed. Not sure where this is going to go but if it comes up in your hearing tomorrow night, you now know where I stand on the issue.

Regards,

Thomas Clancy
Deputy Fire Chief / Fire Prevention Officer
Littleton Fire Department
978-540-2302

From: Maren Toohill
Sent: Friday, May 01, 2020 4:19 PM
To: Tom Clancy <TClancy@LittletonFire.org>; Ed Mullen <emullen@littletonma.org>
Subject: RE: 336 - 338 King St. Water main layout for discussion

Thanks for sharing all the comments on fire protection for 336/338 King Street application.
Maren

From: Tom Clancy
Sent: Thursday, March 19, 2020 11:39 AM
To: Maren Toohill <MToohill@littletonma.org>; Ed Mullen <emullen@littletonma.org>
Subject: FW: 336 - 338 King St. Water main layout for discussion

Thomas Clancy
Deputy Fire Chief / Fire Prevention Officer
Littleton Fire Department
978-540-2302

From: Bruce D. Ringwall [<mailto:BRingwall@gpr-inc.com>]
Sent: Wednesday, March 18, 2020 12:06 PM

To: Tom Clancy <TClancy@LittletonFire.org>
Subject: 336 - 338 King St. Water main layout for discussion

Good day Tom,

I hope you and the department are fairing well in our crazy new world. I've attached a rough layout that Kevin Hunt and I discussed yesterday. If you have a minute please give me a call [978-772-1590] to discuss the latest thoughts and revisions.

Bruce

Bruce D. Ringwall, President
Goldsmith, Prest & Ringwall, Inc.
39 Main Street, Suite 301
Ayer, MA 01432
P 978-772-1590 F 978-772-1591
<mailto:bringwall@gpr-inc.com>
www.gpr-inc.com



This transmission is only for the addressee and may contain information that is privileged and confidential. Unauthorized use, modification, copying, distribution or other disclosure of this transmission and its attachments is strictly prohibited. If you have received this in error, please notify us immediately by phone; then destroy the original. Thank you.

Goldsmith, Prest & Ringwall, Inc.