

Maren Toohill

From: James Garreffii <JGarreffii@nashoba.org>
Sent: Sunday, April 19, 2020 4:36 PM
To: Maren Toohill
Cc: 'nichols.littletonboh@gmail.com'
Subject: RE: Hager Homestead Senior Residential Development

Follow Up Flag: Follow up
Flag Status: Flagged

Maren,

I have reviewed the plans for the Hager Homestead and I have the following comments.

- 1.) The development must be served by a sewage disposal system in compliance with Title 5 and the BOH sewage disposal system regulations. The submission is very light on details on how this will be accomplished.
- 2.) Any blasting materials used shall not be perchlorate-based.
- 3.) All detentions/retention structures shall minimize standing water.
- 4.) All phases of construction shall be done to minimize noise, odor and dust that would be injurious of public health and/or cause a "condition of air pollution."

Jim