

## Amy Green

---

**From:** Shawki, Tony <TShawki@methuenconstruction.com>  
**Sent:** Wednesday, October 11, 2023 2:40 PM  
**To:** Sarah Seaward; Amy Green  
**Cc:** Chase Gerbig; Clauss, Matthew; Czerw, Richard; Casey, Thomas; Kershaw, Lauren C. (Viera); eciKylen@gmail.com; Corey Godfrey; Nick Lawler; 2094 Littleton WRRF  
**Subject:** RE: Fw: Littleton WRRF - Dewatering Discharge Plan  
**Attachments:** IMG\_2106.JPG; IMG\_2105.JPG

\*\*THIS EMAIL WAS SENT BY AN EXTERNAL SENDER\*\*

Hi Sarah,

Some quick updates from today:

- A siphon break has been added (attached picture) to allow for more timing for better sediment settlement inside the frac tank.
- Frac tanks were vacuumed and cleaned out today.
- One bay in the existing basin has been pressure washed and cleaned, other will be done before inspection tomorrow.

Thanks,  
Tony

**Tony Shawki**  
Project Manager  
TShawki@methuenconstruction.com

Main: 603.328.2222  
Mobile: 603.818.0487



144 Main Street | PO Box 980  
Plaistow, NH 03865  
www.methuenconstruction.com

CONFIDENTIALITY NOTICE - This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the system manager. This message contains confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.

**From:** Shawki, Tony <TShawki@methuenconstruction.com>  
**Sent:** Tuesday, October 10, 2023 4:14 PM

10/11/2023 13:26



10/11/2023 13:25

